

**Mandatory Public Notification Language**  
**Notice of Drinking Water HALOACETIC ACIDS Violation**

The Texas Commission on Environmental Quality (TCEQ) has notified the water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for HALOACETIC ACIDS. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for HALOACETIC ACIDS at 0.060 mg/L, and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for HALOACETIC ACIDS in quarter four 2025 indicates a level of .089mg/L for DBP2-01 and .087mg/L DBP2-02.

Haloacetic acids are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing HAA5 in excess of the MCL over many years may have an increased risk of getting cancer.

**You do not need to use an alternative water supply.** However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

**We are taking the following actions to address this issue:**

M-DWSC will be changing our disinfection to use chlorine dioxide.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Millersview-Doole WSC	325-483-5438
13841 FM 1929E PO Box 130	325-483-5462-Fax
Millersview, TX 76862	Cody Giddens

Posted Date / Delivered on: 12/05/2025